

CERTIFICATE OF COMPLIANCE

Certificate Number 20140828-EX2834
Report Reference EX2834-19720524
Issue Date 2014-AUGUST-28

Issued to: GRISWOLD INDUSTRIES, DBA CLA-VAL CO
1701 PLACENTIA AVE COSTA MESA CA 92627

**This is to certify that
representative samples of**


SPECIAL SYSTEM WATER CONTROL VALVES, DELUGE
TYPE
"See Addendum Page"

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 260 - STANDARD FOR DRY PIPE AND DELUGE
VALVES FOR FIRE-PROTECTION SERVICE

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus




CERTIFICATE OF COMPLIANCE

Certificate Number 20140828-EX2834
Report Reference EX2834-19720524
Issue Date 2014-AUGUST-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

The following valves are intended for use in controlling water flow to deluge, pre-action, and foam water sprinkler systems and water spray systems when installed in accordance with the manufacturer's installation instructions.

Listing	Model	Body Type	Nominal Pipe Size, NPS	System Type	Installation Orientation
USL	100G	Globe	3,4,6,8 and 10	Electric Release	Vertical or Horizontal
USL	100GS	Globe	3,4,6,8 and 10	Electric Release	Vertical or Horizontal
USL	2100G	Angle	3,4,6,8 and 10	Electric Release	Vertical or Horizontal
USL	2100GS	Angle	3,4,6,8 and 10	Electric Release	Vertical or Horizontal



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20140828-EX15267
Report Reference EX2834-19890405
Issue Date 2014-AUGUST-28

Issued to: CLA-VAL CANADA CORP
4687 CHRISTIE DR
BEAMSVILLE, ON L0R 1B4 CANADA


**This is to certify that
representative samples of**

SPECIAL SYSTEM WATER CONTROL VALVES, CLASS I
Deluge valves, Models 100G, Globe Style, and 2100G, Angle Style in
the horizontal or vertical installation positions, in nominal pipe sizes 3,
4, 6, 8, 10

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: ULC/ORD-C260 - Guide for the Investigation of Dry Pipe,
Deluge, and Pre-Action Valves for Fire-Protection Service
Additional Information: See the ULC Online Certification Directory at www.ulc.ca
for additional information

Only those products bearing the ULC Listing Mark should be considered as being covered by ULC's
Listing and Follow-Up Service.

The ULC Listing Mark generally includes the following elements: the symbol ULC in a circle:  with
the word "LISTED"; a control number (may be alphanumeric) assigned by ULC; and the product
category name (product identifier) as indicated in the appropriate ULC Directory.

To confirm the status, validate the above information via the online directory.

Look for the ULC Listing Mark on the product.


John Arrabito, Vice President and Treasurer

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized
licensee of ULC. For questions, please contact a local ULC Customer Service Representative at www.ul.com/contactus

