

VLFT.EX2834 - SPECIAL SYSTEM WATER CONTROL VALVES, DELUGE TYPE

Special System Water Control Valves, Deluge Type

See General Information for Special System Water Control Valves, Deluge Type

GRISWOLD INDUSTRIES, DBA CLA-VAL CO

EX2834

1701 PLACENTIA AVE

COSTA MESA, CA 92627-4416 USA

Deluge valves, Models 100G and 100GS, nominal pipe size 3, 4, 6, 8, 10 and 12 NPS, flanged end configuration, globe type, and Models 100G and 100GS, nominal pipe size 3, 4, 6 and 8 NPS, grooved end configuration, globe type intended for horizontal or vertical installation with a pressure rating of 300 psig. For operation manually, electrically, pneumatically and by wet pilot line of sprinklers utilizing the 134-05 trim configuration.

Deluge valves, Model 134-83 and 134-83KX, nominal pipe size, 4 and 6 NPS, flanged and grooved end configurations, globe type, intended for horizontal or vertical installation positions with an inlet pressure rating of 300 psig. For operation manually, electrically and by wet pilot line sprinklers all with pressure reducing feature. Pressure reducing outlet setting pressure range is 50-165 psig for the 4 NPS valve. Pressure reducing outlet setting pressure ranges are 35-90 psig and 50-165 psig for the 6 NPS valve.

Deluge valves, Models 2100G and 2100GS, nominal pipe size 3, 4, 6, 8, 10 and 12 NPS, flanged end configuration, angle type, intended for horizontal or vertical installation with a pressure rating of 300 psig. For operation manually, electrically, pneumatically and by wet pilot line of sprinklers utilizing the 134-05 trim configuration.

Deluge valves, Model 8134-05, nominal pipe size 2, 2-1/2, 3, 4, 6, and 8 NPS, flanged and grooved end configurations, globe type, intended for horizontal or vertical installation with a pressure rating of 200 psig utilizing the 134-05 trim configuration. For Electric Release.

For operation by wet pilot line sprinklers, height of pilot line above the valve to be limited as shown in the Installation Instructions.

For accessories used with these valves, see Listing under "Accessories for Special Systems".

Last Updated on 2018-08-17

并不是所有出现在本数据库中的公司名称和产品都满足了UL跟踪检验服务的要求。只有带有UL标志的产品，才应该被视为经过UL认证，并满足UL跟踪检验服务的要求。注意查看产品上的标志。

UL允许在线认证目录中所含材料的复制遵循以下条件：1.指南信息、装配、构造、设计、系统和/或认证（文件）必须在不篡改任何数据（或图纸）的情况下完整且无误导性地呈现。2.“经UL允许从在线认证目录转载”声明必须出现在所摘取材料的邻近位置。此外，转载材料必须包含以下格式的版权声明：“© 2019 UL LLC”