


-MODEL - 660-73

Booster Pump Control Valve





Schematic Diagram

Item Description

- 1 Powercheck Main Valve 100-31
- 2 CV Flow Control
- 3 CSM11-A2-2 Solenoid Control
- 4 X105LCW Switch Assembly
- 5 CVS-1 Shuttle Valve

Optional Features

Item Description

- A X46A Flow Clean Strainer
- B CK2 Isolation Valve
- Y X43 "Y" Strainer

Simple Hydraulic Operation

- Low Head Loss
- Horizontal or Vertical Mounting
- · Built-in Check Valve
- Proven Reliable Design

The Cla-Val Model 660-73 Booster Pump Control Valve is a pilotoperated valve designed for installation on the discharge of booster pumps to eliminate pipeline surges caused by the starting and stopping of the pump.

The pump starts against a closed valve. When the pump is started, the solenoid control is energized and the valve begins to open slowly, gradually increasing line pressure to full pumping head. When the pump is signaled to shut-off, the solenoid control is de-energized and the valve begins to close slowly, gradually reducing flow while the pump continues to run. When the valve is closed, a limit switch assembly, which serves as an electrical interlock between the valve and the pump, releases the pump starter and the pump stops.


Should a power failure occur, a built-in lift-type check valve closes the moment flow stops, preventing reverse flow regardless of solenoid or diaphragm assembly position.

Typical Installation

Install Model 660-73 valve as shown. Flexible conduit should be used for electrical connections to the solenoid control and the limit switch. The Model 52-02 or 652-03 Surge Anticipator Valve is recommended for power failure protection.

Note:

Valve stem can be located in either vertical up or horizontal position.



Pressure Ratings (Recommended Maximum Pressure - psi)

Valve Body &	Pressure Class				
valve body o	Fla	Threaded			
Grade	Material	ANSI Standards*	150 Class	300 Class	End‡ Details
ASTM A536	Ductile Iron	B16.42	250	640	400
ASTM A216-WCB	Cast Steel	B16.5	285	720	400
UNS 87850	Bronze	B16.24	225	500	400

Note: * ANSI standards are for flange dimensions only. Flanged valves are available faced but not drilled.

‡ End Details machined to ANSI B2.1 specifications.


Valves for higher pressure are available; consult factory for details


Materials

Component	Standard Material Combinations				
Body & Cover	Ductile Iron	Cast Steel	Bronze		
100-31 Sizes (mm)	100 - 250 mm	100 - 250 mm	100 - 250 mm		
Disc Retainer & Diaphragm Washer	Cast Iron Cast Steel		Bronze		
Trim: Disc Guide, Seat & Cover Bearing	Bronze is Standard Stainless Steel is Optional Buna-N® Rubber Nylon Reinforced Buna-N® Rubber Stainless Steel				
Disc					
Diaphragm					
Stem, Nut & Spring					

For material options not listed, consult factory. Cla-Val manufactures valves in more than 50 different alloys.

Dimensional Data





660-73 Series Dimensions (Full Internal Port 100-31) (mm)


Valve Size (mm)	100	150	200	250
A 150 ANSI	353	451	543	660
AA 300 ANSI	368	473	568	695
B Diameter	232	292	400	508
C Maximum	302	387	514	603
D 150 ANSI	176	226	272	_
DD 300 ANSI	184	238	284	_
E 150 ANSI	140	171	184	_
EE 300 ANSI	148	184	197	_
F 150 ANSI	114	140	171	203
FF 300 ANSI	127	159	191	222
H NPT Body Tapping	0.50	0.75	0.75	1.00
J NPT Cover Center Plug	0.50	0.75	0.75	1.00
K NPT Cover Tapping	0.50	0.75	1.00	1.00
Stem Travel	20	28	43	58
Approx. Ship Weight (Kgs)	61	104	218	356
Approx. X Pilot System	483	533	787	914
Approx. Y Pilot System	254	279	457	508
Approx. Z Pilot System	254	279	457	508

660-73	100-31 Pattern: Globe (G), Angle (A), End Connections: Flanged (F) Indicate Available Sizes						
Valve	Inches	4	6	8	10		
Selection	mm	100	150	200	250		
Basic Valve	Pattern	G, A	G, A	G, A	G		
100-31	End Detail	F	F	F	F		
Suggested Flow (gpm)	Maximum	580	1025	2300	4100		
Suggested Flow (Liters/Sec)	Maximum	37	65	145	258		
100-31 Series is the reduced internal port size version of the 100-30 Series.							

CSM11 Solenoid Control Power Consumption

Volts	Amp	eres	Volts	Amperes		Coil
VOILO	7	0.00	Volto			Resistance
DC	Holding	Pull In	AC 60 Hz	Holding	Inrush	Ohms
24	.603	24	24	2.88	25.4	0.5
28	.629	120	120	.575	5.1	14.1
32	.500	208	208	.330	2.93	40
48	.293	240	240	.288	2.54	58
115	.122	440	440	.156	1.38	174
125	.119	480	440	.143	1.27	233
252	.072	2.45				
		Volts Am		eres	Coil	
				VOIIS Allipe		Resistance
			(AC 50 Hz)	Holding	Inrush	Ohms
				.48	4.6	15.7
			220	.24	2.3	66
			240	.22	2.1	88

CSM11 Solenoid Control



How to Order

When Ordering, Please **Specify:**

- 1. Catalog No. 660-73
- Valve Size 2.
- 3. Pattern - Globe or Angle
- 4. **Pressure Class**
- 5. Trim Material
- 6. **Electrical Selection**
- 7. **Desired Options**
- When Vertically Installed 8.
- 9. **Epoxy Coating**

CSM11 Specifications

Enclosure General purpose NEMA Type 3; Aluminum Note: For other enclosures and NEMA Types, consult factory

Body — Aluminum Trim — Stainless Steel Housing

Operating Pressure: Maximum pressure 300 psi,

Coil Insulation Class A (molded)

AC voltage

for higher pressure consult factory. AC or DC

15.4 watts DC voltage 16.8 watts

Pilot System Specifications

Temperature Range

Water to 82°C Max

Materials

Standard Pilot System Materials Pilot Control: Low Lead Bronze Trim: Stainless Steel Type 303 Rubber: Buna-N® Synthetic Rubber

Optional Pilot System Materials Pilot Systems are available with optional Aluminum, Stainless Steel


or Monel materials.

Wiring Diagram


Auto-Off-Hand	=	Selector Switch
1CR	=	Relay, DPST Normally Open
2CR	=	Relay, DPST Normally Open
3CR	=	Relay, TPST Normally Open
SW ₁	=	Switch, Remote Start, Automatic
SW ₂	=	Switch, SPDT, Valve Limit Switch
		Connect to N.C. Terminal
PVS	=	Pilot Valve Solenoid
M	=	Pump Motor Starter

 $\underline{\text{Note:}}$ SW2 and PVS supplied by Cla-Val. All other electrical items supplied by customer. SW2 is included in the X105L switch assembly which is mounted on the pump control valve cover.

Shown In Pump Off Position




Sequence Of Operation




Pump Off...

With pump off, static line pressure is transmitted through strainer "F", shuttle valve "C", solenoid control "A", and speed control "E" to the chamber above the diaphragm, thus holding the valve closed. If power failure occurs when valve is open, the built-in check valve "J" closes immediately to prevent reverse flow.



Starting Cycle...

Starting switch closes, pump starts, solenoid control "A" energizes and shifts allowing fluid from upper diaphragm chamber to drain to atmosphere. High pressure fluid from pump enters strainer "B" and shifts shuttle valve "C", which always supplies the highest pressure from either strainer "B" or "F". High pressure fluid is transmitted to the lower diaphragm chamber and opens the valve. The opening speed of the valve is controlled by speed control "E", which limits the rate fluid is relieved from above the diaphragm.




Stopping Cycle...

Starting switch opens, solenoid control "A" deenergizes and shifts, pump continues to run. High Pressure fluid from the pump is directed above the diaphragm, applying force to close the valve.

The valve closes slowly as fluid from the lower diaphragm chamber is gradually released to atmosphere through speed control "D" and solenoid "A". When the valve closes fully, the limit switch "H" shuts off the pump.

Model 660-73 Flow Chart Uses Basic Valve Model 100-31



	Liquid Volume Displaced from Diaphragm Chamber When Valve Opens or Closes						
Г	Sizes (mm)	100	150	200	250		
660-73		.30 liters	.64 liters	2.0 liters	4.77 liters		

Valve Sizing

Sizing Model 660-73 Booster Pump Control Valves is similar to sizing non-modulating type valves. Simply select the smallest size valve that will handle the pump output at an acceptable head loss for the application.

Do not oversize. Oversizing a Booster Pump Control Valve will nullify its ability to prevent surges caused by the starting and/or stopping of the pump. Maximum flow values are given in the selection table above. For further information on flow characteristics for this valve, reference the 100-31 (660-73) technical data sheet.

Example:

A booster pump station with a rated output of 1000 GPM and 4 psi is an acceptable head loss for the application. The flow chart for the Model 100-31(660-73) indicates that a 250 mm globe valve has less than a 4 psi pressure drop at 3785 liters/second.

Drain Provisions

Each time the valve opens or closes, water is discharged from the solenoid exhaust port, the amount varying with the valve size. Provisions should be made for the disposal of this water. Exhaust tube must be free of any back pressure. Provide an air gap between the solenoid exhaust tube and drain facility.

Optional Electronic Control



The Cla-Val PC-22D provides control of the pump and pump control valve, preventing surges in the system when the pump starts or stops. It consists of a pre-wired electrical control panel employing a programmable valve controller to sequence the pump and pump control valve during all modes of operation. Provides added protection to the pumping system from damage caused by mechanical, hydraulic or power failure.

The PC-22D offers all the control features found in the recommended wiring diagrams for Cla-Val pump control valves, plus alarms, automatic shutdown and adjustable timers.