

# Certificate of Compliance

Certificate Number EX2834 -2008-07-21

Report Reference May 24, 1972

Issue Date 2008 July 21

Page 1 of 1



**Underwriters  
Laboratories Inc.®**

***Issued to:***

**GRISWOLD INDUSTRIES, DBA CLA-VAL CO**

1701 Placentia Ave.  
Costa Mesa, CA 92627

***This is to certify that  
representative samples of***

**Deluge Valves:**

Models 100G, 100GS, 2100G, and 2100GS, 3, 4, 6, 8 and 10 in. sizes for rated pressures not to exceed 175 psi.

***Have been investigated by Underwriters Laboratories Inc.® in accordance  
with the Standard(s) indicated on this Certificate.***

***Standard(s) for Safety:***


UL 260 "Dry Pipe, and Deluge Valves for Fire-Protection Service".

***Additional Information:***

These valves are intended for use in controlling water flow to deluge, pre-action, and foam water sprinkler systems and water spray systems. Deluge valves are intended to be installed in the vertical position only, unless otherwise indicated in the individual listings. These valves shall be provided by the manufacturer with all the necessary "Trim" accessories (i.e., shut-off valves, drains, fittings, etc) and assembly drawings. The valves are required to be installed as specified by the individual manufacturer's installation instructions.

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:

 with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by:

Tracey J. Milton  
Underwriters Laboratories Inc.

Reviewed by:

Michael G. McCormick  
Underwriters Laboratories Inc.