

CERTIFICATE OF COMPLIANCE

Certificate Number 20150513-EX2834
Report Reference EX2834-20150513
Issue Date 2015-MAY-13

Issued to: GRISWOLD INDUSTRIES, DBA CLA-VAL CO
1701 PLACENTIA AVE, COSTA MESA CA 92627-4416

**This is to certify that
representative samples of**

SPECIAL SYSTEM WATER CONTROL VALVES, DELUGE
TYPE

Deluge valves, Model 8000G, 2, 2-1/2 3, 4, 6, and 8 in.
sizes, globe type, horizontal or vertical installation with a
rated pressure rating of 200 psig.

Deluge valves, Models 8134-05, 2, 2-1/2 3, 4, 6, and 8 in.
sizes, globe type, solenoid operated, horizontal or vertical
installation with a rated pressure rating of 200 psig.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 260 - Standard for Dry Pipe and Deluge Valves for Fire
Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

